

From: RM Floods Planning <floods.planning@suffolk.gov.uk>
Sent: 15 April 2019 12:35
To: BMSDC Planning Area Team Yellow <planningyellow@babberghmidsuffolk.gov.uk>
Cc: Alex Scott <Alex.Scott@babberghmidsuffolk.gov.uk>
Subject: 2019-04-15 JS reply Land To The West Of , Ixworth Road, ThurstonDC/18/03547 RM

Dear Alex Scott,

Suffolk County Council, Flood and Water Management have reviewed application ref DC/18/03547.

The following submitted documents have been reviewed and we recommend maintain our **holding objection** at this time:

- Planning Layout Ref 981-P-100 F
- Landscape Masterplan ref JBA 16/053-03 Rev A
- Indicative Pond Planting Sections JBA-16053-11

The reason why we are recommending maintaining our a holding objection is because the applicant has still not supplied sufficient detail of the landscaping of the SuDs features, specifically the attenuation lagoon. The planting of the lagoon should be done in a manner that support and encourages local species, whilst meeting the Ciria SuDs manual pollution indices.

The point below detail the action required in order to overcome our current objection:-

1. Detail landscaping design and planting details of the of SuDs features.

Kind Regards

Jason Skilton
Flood & Water Engineer
Suffolk County Council
Growth, Highway & Infrastructure
Endeavour House, 8 Russell Rd, Ipswich , Suffolk IP1 2BX
Tel 01473 260411



[Enter the Creating the Greenest County Awards!](#)